

PWS ID#: NH1181010



10 Water Works Drive

PO Box 16322

Hooksett, NH 03106

Phone: (603) 624-0608

Fax: (603) 624-0814

Email: centralhooksetwater@comcast.net

Website: www.centralhooksettwater.com

PRECINCT

COMMISSIONERS

William Alois

Everett Hardy

William McDonald

Richard Monteith

Richard Bairam

Commissioner's Meetings are

Held on the 2nd Monday of

Each month at 7:00 pm at the Precinct Office.

Annual Meeting held in March.

Water Quality Report 2016

Water Testing Performed in 2015



Central Hooksett Water Precinct, for a number of years, has been completely supplied by Manchester Water Works with a connection on Zapora Road and on North River Road. Manchester Water Works supplies water from Lake Massabesic located in East Manchester and Auburn, NH.

Please visit the Manchester Water Work's website: <http://www.manchesternh.gov/CCR>, or Central Hooksett Water Precinct's website: www.centralhooksettwater.com, for the latest Manchester Water Quality Report and additional health information and contaminant results.



Please note Central Hooksett Water Precinct office ***has not moved***, but, due to E-911 purposes, we have been given a new address, 10 Water Works Drive. The mailing address, PO BOX 16322, has not changed.



Health Information

Why are contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least a small amount of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Central Hooksett Water Precinct

2015 Contaminant Levels

ONTAMINANT (Units)	MCL	MCLG	Level Detected	VIOLATION	LIKELY SOURCE OF CONTAMINANT	HEALTH EFFECTS OF CONTAMINANT
Chlorine (ppm)	MRDL = 4	MRDLG = 4	.61	NO	Water additive used to control microbes.	Some people who drink water that contains chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort
TTHM (Total Trihalomethanes) (ppb)	80	N/A	3.89	NO	By-product of drinking water chlorination.	Some people who drink water that contains trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.
Haloacetic Acids (ppb)	60	N/A	3.45	NO	By-product of drinking water chlorination.	Some people who drink water that contains haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Definitions:

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. They are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL: Maximum Residual Disinfectant Level or the highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants (for water systems that use chlorine).

MRDLG: Maximum residual disinfectant level goal or the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants (for water systems that use chlorine).

AL: Action Level

ppb: parts per billion

ppm: parts per million